
EASY LIQUIDS MOREE - 2025 MONITORING DATA

EASY Liquids Moree operates subject to Environment Protection Licence (EPL) 21872 which was first issued on May 28, 2024. This licence was varied on April 1, 2025 to include the monitoring requirements below.

The site is located at 709 Carnarvon Highway, Moree, NSW 2400.

Controlled Discharges: EPA Sampling Point 1

The Licence requires pH monitoring on each discharge from the onsite storage tank, listed as EPA Identification "Point 1".

Table 1 below lists monitoring data for the period

The Licence requires monitoring for the pollutants below at "Special Frequency 1" (twice per year) from the onsite storage tank, listed as EPA Identification "Point 1". There are no limits set for this monitoring program.

Table 2 lists monitoring data for the period.

Table 1: Sampling Point 1 pH Monitoring

Table 1: Sampling Point 1 pH Monitoring				
Date & Time		pH (pH Units)	EPA Limits (pH Units)	Compliant (Yes/No)
1/04/2025	12:00	8.38	6.0 – 9.0	Yes
2/04/2025	08:00	8.27	6.0 – 9.0	Yes
2/05/2025	14:00	8.61	6.0 – 9.0	Yes
14/05/2025	10:00	7.84	6.0 – 9.0	Yes
20/05/2025	13:00	7.34	6.0 – 9.0	Yes
23/06/2025	08:00	8.27	6.0 – 9.0	Yes
1/07/2025	15:15	8.95	6.0 – 9.0	Yes
22/07/2025	13:00	8.84	6.0 – 9.0	Yes
28/07/2025	12:00	7.65	6.0 – 9.0	Yes
20/08/2025	09:00	8.67	6.0 – 9.0	Yes
17/09/2025	11:00	7.95	6.0 – 9.0	Yes
23/09/2025	13:00	8.45	6.0 – 9.0	Yes
29/10/2025	12:00	8.92	6.0 – 9.0	Yes
12/11/2025	11.30	7.78	6.0 – 9.0	Yes
24/11/2025	08:00	6.75	6.0 – 9.0	Yes
11/12/2025	12.30	8.91	6.0 – 9.0	Yes

Table 2: Sampling Point 1 Pollutant Monitoring

Pollutant	Unit of Measure	Samples Collected	Result 1	Result 2
Ammonia	mg/L	1	14,800	
Arsenic	mg/L	1	0.039	
BOD	mg/L	1	10,900	
Boron	mg/L	1	0.115	
Cadmium	mg/L	1	<0.001	
Chromium	mg/L	1	0.035	
Copper	mg/L	1	0.382	
EC	uS/cm	1	0.078	
Lead	mg/L	1	0.003	
Manganese	mg/L	1	0.375	
Mercury	mg/L	1	<0.0005	
Nickel	mg/L	1	0.034	
Nitrogen (total)	mg/L	1	1990	
Oil and Grease	mg/L	1	16.5	
pH	pH Units	1	8.48	
Phosphorus (total)	mg/L	1	580	
Potassium	mg/L	1	3,170	
Sodium Adsorption Ratio	-	1	2.7	
Sulfate	mg/L	1	1,880	
TSS	mg/L	1	140	
Zinc	mg/L	1	54.4	



Uncontrolled Discharges: EPA Sampling Point 6

The Licence requires monitoring for the pollutants listed in Table 2 at “Special Frequency 2” (within 24 hours of any uncontrolled discharge) from the premises, listed as EPA Identification “Point 6”.

There are no limits set for this monitoring program.

There have been zero uncontrolled discharges from the site during this period.

Date Published: December 16, 2025