

EASY LIQUIDS WHITTON - 2025 MONITORING DATA

EASY Liquids Whitton operates subject to Environment Protection Licence (EPL) 21852 which was first issued on July 1, 2024.

The site is located at 96 Young Road, Whitton, NSW.

The Licence requires pH monitoring on each discharge from the onsite storage tank, listed as EPA Identification "Point 1".

The Table below lists monitoring data for the period.

Date & Time		pH (pH Units)	EPA Limits (pH Units)	Compliant (Yes/No)
13/01/2025	16:00	7.1	5.0 – 8.5	Yes
21/02/2025	7:00	8.3	5.0 – 8.5	Yes
17/03/2025	7:00	8.4	5.0 – 8.5	Yes
14/05/2025	11:00	7.6	5.0 – 8.5	Yes
02/07/2025	8:00	6.6	5.0 – 8.5	Yes
25/09/2025	7:00	7.7	5.0 – 8.5	Yes
16/10/2025	10:30	7.3	5.0 – 8.5	Yes
15/12/2025	7:00	7.4	5.0 – 8.5	Yes

Date Published: December 16, 2025